


Pipe End Preparation Flexalen®PU

How to remove the casing pipe and the foam insulation of the pre-insulated pipes Flexalen® PU.





Application Instruction


Application conditions and pipe preparation

- Ambient temperature: +5 to +40°C
- Pipe is without damage
- Pipe is free from dirt and condensation




01.

Measure and mark the length of exposed service pipe required for compression connector or electrofusion fitting installation.



a) Installation of compression connector, weld adapter, flange adapter or tread connector and all weldable solutions:

Min. length for all pipe sizes: L1 = 200mm +/- 30mm



b) For service pipe connections (compressed or welded):

Min. length for all pipe sizes: L1 = L2 = 200mm +/- 10mm



Attention: make sure to have enough overlap between sliding socket and casing pipe when using insulation couplers.



02.

Carefully cut the outer casing along the pipe axis up to the marked measurement.

Attention: do not damage the surface of the service pipe.



03.

Carefully cut around the circumference of the casing pipe at the measured mark - again taking care not to damage the service pipe.



04.

Peel back the cut section of the casing pipe.



05.

Carefully remove the PU insulation foam from the service pipe, by using a putty knife.

Attention: do not damage the surface of the service pipe.



06.

To make the pipe end straight, cut 30mm of service pipe with a suitable pipe cutter.

Disclaime



